

Texas Fire Chiefs Association
DOCUMENT SUBMISSION FORM

Candidate Department: Coppel Fire Department

Best Practice Standard: 9.04
(insert the Best Practice Standard you are working on - example "1.01")

Proofs of Compliance Submitted:

--Dispatch equipment is primarily on a battery backup (UPS). UPS equipment is stored inside the secure portion of the communications center. A generator is provided as a secondary means of power to the battery backup. This generator is run and performs a self-test weekly.

Submitted By: Gregg Loyd	Date: 10/1/2013
---------------------------------	------------------------

Evaluator's Review

Evaluator:

Date Accepted: